

**ADDENDUM 1 TO SALINE COUNTY ROAD DEPT. BID FOR PROVIDING AND
ERECTING A 300' LONG BY 40' WIDE EQUIPMENT SHED BID #2018-12-17
REVISED BID SPECIFICATIONS**

Note that the following specifications to Bid #2018-12-17-Providing and Erecting a 300' long by 40' wide Equipment Shed for the Saline County Road Dept. have been revised. Bidders should use the revised bid specifications when submitting their bid.

Specifications - Providing and Erecting a 300' Long by 40' Wide Equipment Shed:

1. Post shall be 6" by 6" Number 2 Southern yellow pine CCA treated for ground contact.
2. Post shall be set in the center of an 18" diameter whole 54" deep with 6" of stone base and backfilled with 3500 psi concrete. The post shall be protected with a 54" long plastic sleeve manufactured by "Post Protector". Post shall be set plumb and on 12' centers along each side of the building and ends or as shown on plans.
3. Bottom splash/skirt grade board shall be 2" by 6" number 2 Southern yellow pine CCA treated for ground contact. Splash/skirt is to run level and be attached to the 6" by 6" post with three appropriately sized and coated wood screws.
4. Grits above the splash/skirt shall be 2" by 6" number 2 Southern yellow pine set on 36" vertical centers. Grits are to run level and be attached to the 6" by 6" post with three appropriately sized and coated wood screws.
5. Secondary framing members for the end walls and the one interior wall and the door opening frames shall be 2" by 6" number 2 Southern yellow pine. These members are to be connected with appropriately sized and coated wood screws.
6. Roof frame members shall be clear span engineered structural steel trusses. The truss design shall be by a professional engineer. The truss plan shall have an engineer's seal and signature. The roof shall have a 4:12 pitch. Truss are to be analyzed based on following loads as defined by IBC 2006/ASCE 7-05. The spacing for the trusses is 12'-0" on centers. The roof deck is supported with 4" by 2-1/2" 16-gauge Zee purlin clip and metal purlins spaced on 48" on centers. Dead load is .5 PSF (roof deck, zee purlins, and truss itself). Live load is 20 PSF. Snow load is 10 PSF (snow load not to occur in combination with live loads). Trusses to be attached to the 6" by 6" post with 5/8" galv. bolts.
7. Roofing deck shall be 26-gauge steel PBR color galvalume attached to the metal purlins with appropriately sized roof screws.
8. Siding shall be 26-gauge steel PBR color Charcoal Gray attached to the splash/skirt and grits with appropriately sized siding screws.
9. Provide two 10' wide by 12' tall garage doors and one 36" wide by 84" tall exterior metal door. All girders/headers are to be 2" by 12" southern yellow pine. All connections are to be made with appropriately sized and coated wood screws.
10. All incidentals materials and labor to make a complete building is to be provided by contractor.
11. Site grading is to be done by owner. It is not a part of this contract.

**ADDENDUM 2 TO SALINE COUNTY ROAD DEPT. BID FOR PROVIDING AND
ERECTING A 300' LONG BY 40' WIDE EQUIPMENT SHED BID #2018-12-17
EXTEND BID OPENING DATE**

BID OPENING LOCATION:

Saline County Courthouse
200 N. Main Street, Suite 116
Benton, AR 72015

Bid Opening Date: December 26, 2018

MAIL BID TO OR DELIVER TO:

Saline County Courthouse
200 N. Main Street, Suite 116
Benton, AR 72015

Time: 10:00 A.M

Instruction to Bidders:

To be considered responsive, Bids must be made in accordance with the following instructions:

1. RECEIPT AND OPENING OF BIDS:

Saline County (hereinafter called the "Owner") invites Bids on the Bid Form attached hereto, all blanks which must be appropriately filled in. Bids will be received by the Saline County Purchasing Specialist, Suite 116, Saline County Courthouse, 200 North Main Street, Benton, Arkansas, until 10:00 a.m. **December 26, 2018.**

The Owner may consider informal any Bid not prepared and submitted in accordance with the provisions hereof and may waive any irregularities or reject any or all Bids. Bids received prior to the time of opening will be kept unopened. No responsibility will be assumed by any person for the premature opening of a Bid not properly addressed and identified, such bids will be rejected. *Any Bid received after the time and date specified will not be considered.*